

KANDLA PORT TRUST

ELECTRICAL DIVISION

Name Of Work :- Providing Lighting arrangement through High Mast Tower in the Newly Developed 34 Hector area.

TENDER NO. EL/AC/1758

Pre-Bid Clarifications

Pre-bid meeting held on : 09/11/2016.

Sr. No.	Clause No	Page No.	As per Tender Condition	Quaries raised	Clarification of KPT
1	Pre-qualif. Criteria	5	Similar Works: Experience in supply or erection, testing and commissioning or both of high mast/mini mast tower lighting cabling work etc. of large Port complex/dock marshaling Yard/air port / Container yard/Depot, production of storage complex of big industrialIndustrial House, Government/Semi Government organisation/ Public Sector Undertaking Org. Public Utility places like stadium etc.	we have executed work of emblem/ signage high masts of 17 to 40 mtrs height at various locations. In general high mast is a tower structure that can be provided with light fittings to illuminate the area. Where as in signage masts , we provide sign boards on the Cradle. Hence, request to consider the same (i.e. Signage Highmasts) as similar works.	Tender condition holds good.
2	Clause No. 17 of GCC, Section-II	32	Subcontracts: The Contractor shall not be allowed to engage any sub-contract for all or any part of this contract.	The subject work is execution work , we being a manufacturer, this type of work will be executed through our local autorised dealer/ channel parner having valid Electrical contractor licenceand require experience. hence, kindly consideras of the follow (a) whether incorporate the subletting/sub contracting clause (OR) (b) Permit us to qoute through our dealer/ partner with the credentials of our principle employer.	The work may be executed through Sub Contractor. The contractor shall allow to engage sub contract for all work, as per Guideline of CVC . However same may be obtained permission from CME, KPT. The BID can not be submitted through authorized dealer/channel partner. The bidder should have valid Electrical Contractor Licenece.
3	Tech. Spec. No:-01 of Section-V	81	Rubberised multi-core, multi stand, flat/ Round copper conductor cable (5cx16 sq.mm coper)	It shall not be possible to house such thick in the pulley of the head frame, instead two cables 5 Cx4 sq.mm shall be provided.	Agreed, as per the manufacture design of the High Mast. However, current carrying capacity of the cable shall be as per load requirement.
4	Tech. Spec. No:-07 of Section-V	90	TECHNICAL SPECIFICATION OF ITEM NO. 4a(I) & b(I) (i) (1 X 1000 Watt Fixture Asymmetrical Type) and (ii) 1 X 1000 Watt Fixture For Symmetrical arrangement	Technical spcification of the Light fixture seems favoring few of the manufacturers. Kindly generalise the specification to accomidate other manufacturers like Surya,CGL,C&S,Wipro etc.	Tender condition holds good. Specification is already generic. List of approved make is included in tender.
5	Item No. 3 of BOQ (Part-B) of Section-IV	104	---	Kindly provide detail specification of the following Civil works 3(A),(C) & (D).	Specification of the following may read as under. 3(A). For each High Mast foundation , 4 Nos. of Piles will be required , for carrying out piles work , piling equipment shall be shifted at each High Mast location shown in the Drawing. 3 (C). Boring up to 20 Mtr below ground level with Diameter suitable for 400 mm piling shall be done for 17 nos. , High Mast with 4 nos. piling each.

					3(D) The Piles shall be lined for equidistance & uniformly . They shall be cut & level for uniform load bearing.
6	---	---	---	Approved make list for various items required to carryout the costing.	Approved make list for various items is provided at Annexure-I.
7	---	---	---	Approval of Surya brand in subject Tender.	Agreed .
8	Clause No. 15 of GCC, Section-II	31	Taxes	Clarification of KPT	The party has to quote the liability of VAT, Service Tax separately and the same will be paid/reimbursed by KPT as per rates prevailing on the date of opening of tender. Any subsequent increase in the tax rate or introduction of new tax, will be paid by KPT. Similarly, any benefit arising due to downward/revision in the tax, rates or any exception availed in the taxes by the bidder due to introduction of GST, shall be passed on to KPT. The bidder may quote the rates on online system in BOQ including all taxes, duties, rates, charges etc. but excluding service tax. However, the bidder shall indicate separately on their letter pad, various rate of taxes considered on relevant element of cost presently applicable in their offer in detail so as to evaluate increase/ decrease of such taxes on implementation of GST in India. Scanned copy of document for the same is required to be provided in Stage-III (Commercial bid).
9	Clause No. 4.1.c of ITB, Section-I	9	Bid Capacity	Clarification of KPT	Index for FY 2015-16 may be read as 176.70 instead of 182.60.

sd-
SE(E)(I/c

sd-
SE(H)

sd-
FA & CAO

sd-
CME